

Message

From: Matlock, Dennis [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=7EB30E129A9246E5B47301D1D0622A15-DMATLOCK]
Sent: 9/29/2017 12:51:48 PM
To: Towle, Michael [Towle.Michael@epa.gov]
Subject: Re: Newest PCE Test Results

Thx

Sent from my iPhone

On Sep 29, 2017, at 7:08 AM, Towle, Michael <Towle.Michael@epa.gov> wrote:

FYI. Public water just fine.

Sent from my iPhone

Begin forwarded message:

From: Josh Billiter <josh.billiter.padencity@gmail.com>
Date: September 29, 2017 at 7:02:58 AM EDT
To: Lewis Baker <lewbaker@wvrwa.org>, "Smith, Bob A" <Bob.A.Smith@wv.gov>, Towle.michael@epa.gov
Subject: Newest PCE Test Results

Got new testing results from Sept 14, 2017

Raw Water (pre stripper)	8.16
Finished Water (post stripper)	0.380
Public Sites	
53 Carmen Ln	0.410
310 South 4th Ave	0.500

If my math is correct we are removing 95% of the contaminant through the air stripping process.

Just a wanted to let everyone know where we stand at this moment. Will be testing again in October hopefully more of the same, but time will tell.

Thanks
Josh Billiter
Paden City Water Works